



Commitment to Comply with the Arizona Department of Environmental Quality

Public water systems (PWSs) must Monitor and Sample for the following:

Lead and Copper (Pb/Cu)

Systems required to sample for initial monitoring: 10 samples must be collected between January 31-June 30 and again between July 1-December 31.

On March 26, 2025, ADEQ conducted an inspection and found the required monitoring and sampling had not been done for the following:

PWS ID #AZ0404040

Violation Type:

Lead and Copper (Pb/Cu)

Date of Violation of Contaminant: N/A.

Date Public Notice of Violation of Contaminant was distributed: *Need to submit for most recent round of sampling*

Verde Glen DWID commits to: complete initial sampling for Pb/Cu Lead and Copper at 10 sample locations between January 1, 2025 – June 30, 2025 and again July 1, 2025-December 31, 2025.

**I certify that the above information is true and accurate to the best
of my knowledge:**

Name and Title (PRINT)

Signature Date

Certified Operator # (if applicable)

